



**NOTIFICATION**

The following notification is being circulated in accordance with Article 10.6

<b>1. Notifying Member:</b> <u>THAILAND</u> <b>If applicable, name of local government involved (Article 3.2 and 7.2):</b>
<b>2. Agency responsible:</b> Thai Industrial Standards Institute (TISI) <b>Name and address (including telephone and fax numbers, email and website addresses, if available) of agency or authority designated to handle comments regarding the notification shall be indicated if different from above:</b>  WTO/TBT Enquiry Point and Notification Authority, Thai Industrial Standards Institute (TISI), Ministry of Industry Tel.: (662) 202 3504, 202 3523 Fax: (662) 202 3511, 354 3041 E-mail: <a href="mailto:thaitbt@tisi.go.th">thaitbt@tisi.go.th</a> Website: <a href="http://www.tisi.go.th">http://www.tisi.go.th</a>
<b>3. Notified under Article 2.9.2 [X], 2.10.1 [ ], 5.6.2 [ X ], 5.7.1 [ ], other:</b>
<b>4. Products covered (HS or CCCN where applicable, otherwise national tariff heading. ICS numbers may be provided in addition, where applicable):</b> Electrical apparatus for switching or protecting electrical circuits, or for making connections to or in electrical circuits (for example, switches, fuses, lightning arresters, voltage limiters, surge suppressors, plugs, junction boxes), for a voltage exceeding 1,000 volts. (HS 8535). Fuses and other overcurrent protection devices (ICS 29.120.50).
<b>5. Title, number of pages and language(s) of the notified document:</b> Notification of the Ministry of Industry No. ... (B.E. 2560) Issued under the Industrial Product Standards Act B.E. 2511(1968): Amending to Thai Industrial Standard for Residual Current Operated Circuit-Breakers without Integral Overcurrent Protection for Household and Similar Uses (RCCBS)- Part 1: General Rules (Amendment No. 1) (120 page(s), in Thai)
<b>6. Description of content:</b> The Thai Industrial Standards Institute (TISI) has proposed to amend the Thai Industrial Standard for residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBS)- Part 1: General Rules.  This standard applies to residual current operated circuit-breakers functionally independent of, or functionally dependent on, line voltage, for household and similar uses, not incorporating overcurrent protection (hereafter referred to as RCCBs), for rated voltages not exceeding 440 V a.c. and rated currents not exceeding 125 A, intended principally for protection against shock-hazard.  The main amendment includes standard values of rated residual operating current, which modified to be 0.006 - 0.01 - 0.015 - 0.03 - 0.1 - 0.2 - 0.3 - 0.5 - 1 A as stated in 5.3.3.

<b>7. Objective and rationale, including the nature of urgent problems where applicable:</b> Other; Safety
<b>8. Relevant documents:</b> <ul style="list-style-type: none"><li>• IEC 61008-1 Edition 2.1: 2002 Residual Current Operated Circuit-Breakers without Integral Overcurrent Protection for Household and Similar Uses (RCCBS) Part 1: General rules</li><li>• TIS 909-2548 (2005) Residual Current Operated Circuit-Breakers with Integral Overcurrent Protection for Household and Similar Uses (RCBOs)</li><li>• TIS 2162-2547 (2004) Plugs and Socket-outlets for Household and Similar Purposes-Part 1: General Requirements</li></ul>
<b>9. Proposed date of adoption:</b> To be determined <b>Proposed date of entry into force:</b> To be determined
<b>10. Final date for comments:</b> 60 days from notification
<b>11. Texts available from: National enquiry point [X] or address, telephone and fax numbers and email and website addresses, if available, of other body:</b>  Thailand WTO/TBT Enquiry Point and Notification Authority Thai Industrial Standards Institute Tel: (66 2) 202 3504, 202 3523 Fax: (66 2) 202 3511, 354 3041 E-mail: <a href="mailto:thaitbt@tisi.go.th">thaitbt@tisi.go.th</a> <a href="https://members.wto.org/crnattachments/2017/TBT/THA/17_2768_00_x.pdf">https://members.wto.org/crnattachments/2017/TBT/THA/17_2768_00_x.pdf</a>